State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

| System Name WESTERN HILLS MH ESTATES PWS ID# 4 1 01172 | | | | | | | |
|---|-------------|------------------|---|---|--------------------------|-------------------------|--|
| Month/ | | 0/2023 Entry Po | int: D | Required Minimum Residual 0.40 mg/L | | | |
| Date | Time | Source(s) in use | | Lowest free chlorine residual at entry point to distribution system (mg/L |) | Notes | |
| 1 | 10:00P | Wells 5&6 | | 0.59 | | | |
| 2 | 11:50A | Wells 5&6 | | 0.55 | | | |
| 3 | 06:40A | Wells 5&6 | | 0.56 | | | |
| 4 | 03:00A | Wells 5&6 | | 0.57 | | | |
| 5 | 01:00A | | Wells 5&6 | | | | |
| 6 | 11:00A | Wells 5&6 | | 0.78 | | | |
| 7 | 10:00A | Wells 5&6 | | 0.81 | | | |
| 8 | 11:00A | Wells 5&6 | | 0.79 | | | |
| 9 | 10:00P | Wells 5&6 | | 0.72 | | | |
| 10 | 11:00P | Wells 5&6 | | 0.63 | | | |
| 11 | 11:20A | Wells 5&6 | | 0.58 | | | |
| 12 | 03:00P | Wells 5&6 | | 0.68 | | | |
| 13 | 12:00A | Wells 5&6 | | 0.93 | | | |
| 14 | 04:00A | Wells 5&6 | | 1.22 | | | |
| 15 | 06:00A | Wells 5&6 | | 1.32 | | | |
| 16 | 12:00P | Wells 5&6 | | 1.37 | | | |
| 17 | 04:00P | Wells 5&6 | | 1.31 | | | |
| 18 | 11:00P | Wells 5&6 | | 1.25 | | | |
| 19 | 11:00P | Wells 5&6 | | 1.18 | | | |
| 20 | 11:00P | Wells 5&6 | | 1.12 | | | |
| 21 | 10:00P | Wells 5&6 | | 1.08 | | | |
| 22 | 02:00A | Wells 5&6 | | 1.06 | | | |
| 23 | 11:00P | Wells 5&6 | | 0.66 | | | |
| 24 | 12:50P | Wells 5&6 | | 0.41 | | | |
| 25 | 12:00A | Wells 5&6 | | 0.66 | + | | |
| 26 | 02:00A | Wells 5&6 | | 1.15 | + | | |
| 27 | 08:00A | Wells 5&6 | | 1.21 | + | | |
| 28 | 11:00P | Wells 5&6 | | 1.09 | + | | |
| 29 | 11:00P | Wells 5&6 | | 0.93 | | | |
| 30 | 10:00P | Wells 5&6 | | 0.77 | + | | |
| 31 | 10:00P | Wells 5&6 | | 0.62 | + | | |
| | | | | | | | |
| Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L? Yes No If yes, what was the longest time period until the required level was restored? 0 hours – If > 4 hours, Drinking Water Program to be notified by end of next business day. | | | | | | | |
| GWS Serving 3,300 or Fewer GWS Serving More Than 3,300 | | | | | | | |
| If yes, did you monitor every four hours until the residual returned to 0.40 mg/L as required? | | | Did continuous monitoring equipment fail at any time this reporting month? Yes No If yes, were grab samples collected every four hours until the | | | 1 | |
| | | | | | | | |
| | | | | | | | |
| Attach those results and submit them with | | | continuous monitoring equipment was returned to service as | | Date it was returned to | | |
| this form. | | | required? Yes No | | | service: | |
| Attach grab sample results and submit them with this form. | | | | | | | |
| Printed I | Name: JJ Ol | | | tle: Compliance Manager Operator | | Certification #: 766039 | |
| Signature: | | | | | OR | | |
| Date: 11 / 07 / 2023 | | | | | Small Groundwater System | | |