## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name WESTERN HILLS MH ESTATES PWS ID# 4 1 01172						1172
Month/Year 04/2024 Entry Point: D Required Minimum Residual 0.40 mg/L						
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	06:35P	Wells 5&6		0.86		
2	11:08P	Wells 5&6		0.75		
3	01:08P	Wells 5&6		0.69		
4	10:38P	Wells 5&6		1.23		
5	06:39P	Wells 5&6		1.07		
6	10:43P	Wells 5&6		0.89		
7	11:55P	Wells 5&6		0.77		
8	11:48P	Wells 5&6		0.65		
9	05:59P	Wells 5&6		0.57		
10	07:04P	Wells 5&6		1.65		
11	02:49A	Wells 5&6		1.90		
12	06:50A	Wells 5&6		2.06		
13	10:52A	Wells 5&6		2.13		
14	10:53A	Wells 5&6		2.18		
15	02:54P	Wells 5&6		2.20		
16	02:54P	Wells 5&6		2.18		
17	10:56A	Wells 5&6		2.13		
18	06:56P	Wells 5&6		2.14		
19	10:56A	Wells 5&6		2.09		
20	10:58A	Wells 5&6		2.09		
21	02:58P	Wells 5&6		2.12		
22	10:18A	Wells 5&6		1.62		
23	11:00A	Wells 5&6		1.86		
24	07:01P	Wells 5&6		1.88		
25	11:01P	Wells 5&6		1.81		
26	07:02P	Wells 5&6		1.67		
27	11:03P	Wells 5&6		1.51		
28	11:03P	Wells 5&6		1.37		
20	11:03P	Wells 5&6		1.22		
30	11:13P	Wells 5&6		1.07		
31	11.101			1.07		
Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L? Yes No If yes, what was the longest time period until the required level was restored? 2.5 hours hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to 0.40 mg/L as required? Yes No Attach those results and submit them with this form.			Did continuous monitoring equipment fail at a reporting month? Yes No If yes, were grab samples collected every fou continuous monitoring equipment was returned			
						Date continuous monitoring equipment failed:
						/ / Date it was returned to
			required? Yes No Attach grab sample results and submit them		with this form.	service: / /
Printed Name: JJ Olson			Title: Compliance Manager		Operator Certification #: 766039	
Signatur	.σ.	Callron Olan			OR	
-		Jeffrey Olso,	FIIU	$\pi$ . (000) 00+-0000	<b>.</b>	
Date: 05 / 09 / 2024 Small Groundwater System						roundwater System