

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name WESTERN HILLS MH ESTATES

PWS ID# 4 1 01172

Month/Year 08/2024 Entry Point: D

Required Minimum Residual 0.40 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:47A	Wells 5&6	0.56	
2	03:47A	Wells 5&6	1.63	
3	03:47A	Wells 5&6	2.37	
4	01:57P	Wells 5&6	2.50	
5	07:47P	Wells 5&6	2.45	
6	11:47A	Wells 5&6	2.37	
7	11:47P	Wells 5&6	2.31	
8	11:47A	Wells 5&6	2.28	
9	01:00P	Wells 5&6	2.24	
10	09:00A	Wells 5&6	2.24	
11	09:00A	Wells 5&6	2.24	
12	01:00P	Wells 5&6	2.20	
13	05:00P	Wells 5&6	2.18	
14	05:00P	Wells 5&6	2.04	
15	01:00A	Wells 5&6	2.30	
16	11:50P	Wells 5&6	2.56	
17	09:00P	Wells 5&6	1.84	
18	09:00P	Wells 5&6	1.33	
19	09:02P	Wells 5&6	1.04	
20	09:02P	Wells 5&6	0.88	
21	11:22P	Wells 5&6	0.79	
22	07:52P	Wells 5&6	0.72	
23	11:52P	Wells 5&6	0.64	
24	10:12A	Wells 5&6	0.61	
25	01:02A	Wells 5&6	0.99	
26	09:02P	Wells 5&6	0.96	
27	09:02P	Wells 5&6	0.84	
28	02:12P	Wells 5&6	0.73	
29	10:12A	Wells 5&6	0.74	
30	11:12A	Wells 5&6	0.76	
31	12:03P	Wells 5&6	0.72	

Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.40 mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.


Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: JJ Olson

Signature: 

Date: 09 / 09 / 2024

Title: Compliance Manager

Phone #: (503) 554-8333

Operator Certification #: 766039

OR

Small Groundwater System