

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name WESTERN HILLS MH ESTATES

PWS ID# 4 1 01172

Month/Year 07/2025

Entry Point: D

Required Minimum Residual 0.40 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	03:00P	Wells 5&6	1.89	
2				BWN
3				BWN
4				BWN
5				BWN
6				BWN
7				BWN
8				BWN
9				BWN
10	11:11A	Wells 5&6	0.98	BWN
11	12:11A	Wells 5&6	0.71	BWN
12	11:00P	Wells 5&6	0.87	BWN
13	09:40A	Wells 5&6	0.76	BWN
14	03:00P	Wells 5&6	0.72	BWN
15	09:20A	Wells 5&6	0.68	BWN
16	02:30P	Wells 5&6	0.67	
17	10:20A	Wells 5&6	0.68	
18	03:00A	Wells 5&6	0.94	
19	11:00A	Wells 5&6	1.12	
20	11:00a	Wells 5&6	1.19	
21	03:00P	Wells 5&6	1.17	
22	03:00P	Wells 5&6	1.16	
23	11:00A	Wells 5&6	1.15	
24	11:00A	Wells 5&6	1.18	
25	03:00P	Wells 5&6	1.17	
26	11:00A	Wells 5&6	1.18	
27	11:00A	Wells 5&6	1.13	
28	11:00A	Wells 5&6	1.13	
29	11:00A	Wells 5&6	1.13	
30	11:00A	Wells 5&6	1.16	
31	11:00P	Wells 5&6	0.88	

Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.40 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Curtis Olson

Title: Operations Manager

Operator Certification #: 216644

Signature: Curtis Olson

Phone #: (503) 554-8333

OR

Date: 08 / 10 / 2025

Small Groundwater System ☐