

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name WESTERN HILLS MH ESTATES

PWS ID# 4 1 01172

Month/Year 08/2025

Entry Point: D

Required Minimum Residual 0.40 mg/L

| Date | Time   | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|--------|------------------|----------------------------------------------------------------------------|-------|
| 1    | 09:40P | Wells 5&6        | 0.77                                                                       |       |
| 2    | 01:20P | Wells 5&6        | 0.73                                                                       |       |
| 3    | 03:10P | Wells 5&6        | 0.68                                                                       |       |
| 4    | 03:50P | Wells 5&6        | 0.67                                                                       |       |
| 5    | 09:40A | Wells 5&6        | 0.65                                                                       |       |
| 6    | 02:50P | Wells 5&6        | 0.65                                                                       |       |
| 7    | 02:49P | Wells 5&6        | 0.59                                                                       |       |
| 8    | 09:50A | Wells 5&6        | 0.61                                                                       |       |
| 9    | 03:50P | Wells 5&6        | 0.60                                                                       |       |
| 10   | 10:10A | Wells 5&6        | 0.59                                                                       |       |
| 11   | 10:20A | Wells 5&6        | 0.63                                                                       |       |
| 12   | 11:00A | Wells 5&6        | 0.73                                                                       |       |
| 13   | 01:10p | Wells 5&6        | 0.66                                                                       |       |
| 14   | 02:50P | Wells 5&6        | 0.64                                                                       |       |
| 15   | 01:50A | Wells 5&6        | 0.69                                                                       |       |
| 16   | 01:10P | Wells 5&6        | 0.71                                                                       |       |
| 17   | 09:29A | Wells 5&6        | 0.71                                                                       |       |
| 18   | 10:50A | Wells 5&6        | 0.70                                                                       |       |
| 19   | 09:30A | Wells 5&6        | 0.70                                                                       |       |
| 20   | 11:30A | Wells 5&6        | 0.72                                                                       |       |
| 21   | 10:10A | Wells 5&6        | 0.69                                                                       |       |
| 22   | 10:30A | Wells 5&6        | 0.71                                                                       |       |
| 23   | 10:40A | Wells 5&6        | 0.73                                                                       |       |
| 24   | 03:20A | Wells 5&6        | 0.70                                                                       |       |
| 25   | 10:00A | Wells 5&6        | 0.72                                                                       |       |
| 26   | 11:20A | Wells 5&6        | 0.69                                                                       |       |
| 27   | 01:40P | Wells 5&6        | 0.54                                                                       |       |
| 28   | 12:40A | Wells 5&6        | 0.75                                                                       |       |
| 29   | 03:01P | Wells 5&6        | 1.06                                                                       |       |
| 30   | 06:01P | Wells 5&6        | 1.11                                                                       |       |
| 31   | 03:01P | Wells 5&6        | 1.05                                                                       |       |

Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.40 mg/L as required? ☐ Yes ☐ No

*Attach those results and submit them with this form.*

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

*Attach grab sample results and submit them with this form.*

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Curtis Olson

Title: Operations Manager

Operator Certification #: 216644

Signature: Curtis Olson

Phone #: (503) 554-8333

OR

Date: 09 / 10 / 2025

Small Groundwater System ☐