

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Western Hills Mobile Home Estates

PWS ID# 4 1 01172

Month/Year \_01/2026


Entry Point: D

Required Minimum Residual 0.40 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	16:07	Wells 5&6	0.87	
2	17:43	Wells 5&6	0.8	
3	12:56	Wells 5&6	0.65	
4	13:05	Wells 5&6	0.79	
5	15:37	Wells 5&6	0.68	
6	20:55	Wells 5&6	0.77	
7	16:32	Wells 5&6	0.78	
8	20:32	Wells 5&6	0.9	
9	15:05	Wells 5&6	0.8	
10	18:29	Wells 5&6	0.84	
11	18:26	Wells 5&6	0.76	
12	16:37	Wells 5&6	0.57	
13	16:13	Wells 5&6	0.46	
14	16:19	Wells 5&6	0.72	
15	14:55	Wells 5&6	0.44	
16	14:41	Wells 5&6	0.64	
17	15:40	Wells 5&6	0.54	
18	16:05	Wells 5&6	0.45	
19	15:50	Wells 5&6	0.44	
20	16:08	Wells 5&6	0.46	
21	15:48	Wells 5&6	0.43	
22	20:04	Wells 5&6	0.74	
23	13:39	Wells 5&6	0.59	
24	14:45	Wells 5&6	0.55	
25	15:30	Wells 5&6	0.55	
26	16:15	Wells 5&6	0.65	
27	15:45	Wells 5&6	0.56	
28	15:15	Wells 5&6	0.57	
29	12:30	Wells 5&6	0.59	
30	21:01	Wells 5&6	0.58	
31	12:30	Wells 5&6	0.37	See attached Form

Was the chlorine residual ever less than the required minimum residual of .40 mg/L? Yes  No  
 If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day. 1 hour 10 min.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to .40 mg/L as required? Yes No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? Yes No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:</p> <p align="center">/ /</p> <p>Date it was returned to service:</p> <p align="center">/ /</p>
---	---	---

Printed Name: Bryan McConnell Signature:  Date: 02 / 2 / 2026	Title: DRC Phone #: (360) 430-8508	Operator Certification #: 71316 OR Small Groundwater System
--	---------------------------------------	---

On January 31 2026, at 12:00 pm Chlorine residual dropped to 0.373 mg/l. At 13:10 pm on January 31 Chlorine residual was back up to 0.84 mg/l.

Grab sample taken in distribution system at designated sample point showed a chlorine residual of 0.85 mg/l at 14:50 on January 31.