## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Beaver Creek RV Re	sort	PWS ID# 4 1 01333		
Month/Year _01/2021 Entry Point: Well #2 EP-B Required Minimum Residual 1.2 mg/L						
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L		Notes
1	0835			1.7		
2	0900			1.7		
3	0900			1.6		
4	0900		-	1.5		
5	1125			1.5		
6	0900			1.5		9
7	0800			1.3		
8	0840			1.3		
9	0900			1.3		
10	0900			1.5		
11	0900			1.5		
12	0830			1.5		
13	0830			1.5		
14	0845			1.4		
15	0845			1.4		
16	0900			1.4		
17	0845			1.4		
18	0345			1.4		
19	0840			1.6		
20	0910			1.5		
21	0930			1.5		
22	0830			1.4		
23	0900			1.4		
24	0912			1.4		
25	0810			1.3		
26	0845			1.3		
27	0900			1.2		
28	0855			1.5		
29	0900			1.4		3
30	0930			1.5		
31   1600   1.5						
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L?   Yes   No						
If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						00
	lid you monit e residual retu	or every four hours urned to mg/L?	Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No		any time this	Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  Yes No		/ / Date it was returned to service:	
Attach grab sample results and submit them with this form.						/ /
Printed N	Name: Paul C	Suffney //	Title: Manager		Operator Certification #:	
Signature	e: Fau	1 Cull	Phone #: (541) 479-7445		OR	
Date: 02	2 / 04 / 2021				Small Groundwater System ⊠	