State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Beaver Creek RV Res	ort	PWS ID# 4 1 01333		
Month/	Year _08	/2021 Entry Poi	nt: EP-B	Required Minimum Residual 1.2 mg/L		
Date	Time	Source(s) ir	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	0840			1.2		
2	0910			1.2		
3	0900			1.2		
4	0900			1.2		
5	0910			1.5		
6	0840			1.5		
7	0830			1.8		
8	0900			1.8		8
9	0900			1.8		
10	0910			1.8		,
11	0840			1.6		
12	0830			1.8		
13	0830			1.8		
14	0900			1.5		
15	0830			1.5		
16	0900			1.4		
17	0910			1.3		
18	0900			1.3		
19	0855			1.2		
20	0840			1.2		
21	0830			1.4		
22	0900			1.4		
23	0900			1.4		
24	0910			1.3		
25	0900			1.3		
26	0845			1.2		
27	0830			1.2		
28	0840			1.2		
29	0830			1.2		
30	0900			1.3		
31	0900			1.3		
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
			Did continuous monitoring equipment fail at a		•	Date continuous monitoring
If yes, did you monitor every four hours until the residual returned to mg/L?			reporting month? Yes No		iny une uns	equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hor continuous monitoring equipment was returned to Yes No			Date it was returned to service:
			Attach grab sample results and submit them with		with this form.	1 1
Printed I	Name: Paul (Cuffney	7 Titl	e: Manager	Operator Certification #:	
Signature: Phone #: (541) 479-7445					OR	
		1		(01.1)		
Date: 09 / 07 / 2021 Small Groundwater System ⊠						