## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Beaver Creek RV Res	ort	PW	PWS ID# 4 1 01333		
Month/Year _11/2021 Entry Point: EP-B Required Minimum Residual 1.2 mg/L							
Date	Time	Source(s) ir	use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	0900			1.9			
2	0930			1.7			
3	0845			1.7			
4	0850			1.6			
5	0900			1.5			
6	0900			1.4			
7	0955			1.4			
8	0915			1.4			
9	0915			1.3			
10	0850	-		1.3			
11	0845			1.2			
12	0840			1.2			
13	0900			1.3			
14	0915			1.3			
15	0855			1.5			
16	0910			1.4			
17	1010			1.3			
18	0845			1.2			
19	0930			1.2			
20	0900			1.2			
21	0900			1.2			
22	0915			1.5			
23	0850			1.3			
24	0920			1.3			
25	0900			1.5	-		
26	0930			1.4			
27	0930			1.3			
28	0900			1.3			
29 30	0900			1.5	-		
31	0010			1.0	-		
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No							
If yes, what was the longest time period until the required level was restored?							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
	_					1	
	did you moni e residual ret	tor every four hours curned to mg/L?	Did continuous monitoring equipment fail at any time treporting month? ☐ Yes ☒ No		ny time this	Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  Yes No			/ / Date it was returned to servi <del>ce</del> :	
			Attach grab sa	Attach grab sample results and submit them with this form.		≈1 1	
Printed Name: Paul Cuffney Title: Manager					Operator Certification #:		
Signature: Phone #: (541) 479-7445					OR		
Date: 12 / 01 / 2021					Small Groundwater System ⊠		