State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Beaver Crock RV Res	ort	₽₩	PWS ID# 41 01333		
Month/Year _02/2022 Entry Poi			nt: EP-B	Required Minimum Residual 1.2 mg/L			
Date	Time	Source(s) ir	use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	0910			1.6			
2	0845			1.6			
3	0900			1.4			
4	0845			1.4			
5	0900			1.7			
6	0930			1.5			
7	0930			1.8			
8	0910		*	1.8			
9	0845			1.7		ŕ	
10	0900			1.7			
11	0900			1.7			
12	1030			1.5			
13	0915	1	•	1.5			
14	0900			1.4			
15	0855			1.3			
16	0910			1.3			
17	0930			1.2			
18	0855			1.2			
19	0900			1.2			
20	0915			1.2			
21	0915			1.5			
22	0850			1.5			
23	0930			1.4			
24	1020			1.4			
25	0930			1.3			
26	0940			1.3			
27	0930			1.2			
28	0910			1.2			
29							
30							
31							
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No		ny time this	Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? Yes No Attach grab sample results and submit them with this form.		ed to service?	Date it was returned to service:	
Printed Name: Paul Coffney					Operator Certification #:		
Signature: Phone #: (541) 479-7445					OR		
				,	Small Gr	oundwater System 🖂	
Date: 03 / 09 / 2022 Small Groundwater System 🖂							