State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Beaver Creek RV Resort				PWS ID# 4 1 01333			
Month/Year _06/2022 Entry Point: EP-B Required Minimum Residual 1.2 mg/L							
Date	Time	Source(s) ir	use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	0900			1.3			
2	0850			1.3			
3	0900			1.2			
4	0915			1.2			
5	0915			1.2			
6	0900			1.2			
7	0910			1.2			
8	0900			1.3			
9	1030			1.3			
10	0900			1.2			
11	0900			1.5			
12	0830			1.5			
13	0900			1.2			
14	0930			1.2			
15	0915			1.4			
16	0930			1.2			
17	0930			1.2			
18	0930			1.2			
19	1300			1.2			
20	0915			1.2			
21	0910			1.2			
22	0855			1.2			
23	1010			1.4			
24	0830			1.3			
25	0900			1.2			
26	0830			1.2			
27	0840			1.5			
28	0910			1.5			
29	0900			1.4			
30	0950			1.4			
31							
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours							
GWS Serving 3,300 or Fewer				GWS Serving More Than 3,30			
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time treporting month? Yes No		iny time this	Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			If yes, were grab samples collected every four continuous monitoring equipment was returned Yes No			Date it was returned to service:	
			Attach grab sample results and submit them v		with this form.	1 1	
Printed	Name: Paub	Cuffney	Tit	Title: Manager		Operator Certification #:	
Signature: Name Culty Pho				one #: (541) 479-7445	OR		
Date: 07 / 18 / 2022					Small Gr	oundwater System 🖂	