State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Beaver Creek RV Res	sort	PWS ID# 4 1 01333		
Month/	Year _07	7/2022 Entry Po	int: EP-B	Req	quired Minimum	Residual 1.2 mg/L
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L))	Notes
1	0900			1.2		
2	1010			1.2		
3	0855			1.3		
4	0920			1.3		
5	0810			1.2		
6	1030			1.5		
7	0925			1.5		
8	0910			1.4		
9	0900	×		1.4		
10	0930			1.3		
11	0855			1.5		
12	0850			1.5		
13	0840			1.4		
14	0850			1.4		
15	0900			2.0		
16	0900			1.5		
17	0900			1.5		
18	0935			1.4		
19	0840			1.4		
20	0900			1.3		
21	0855			1.3		
22	0900			2.0		
23	0915			2.0		
24	0900			1.7		
25	0930			1.5		
26	0815			1.5		
27	0900			1.4		
28	1010			1.2		
29	0835			1.5		
30	0900	~		1.3		
31	0915			2.0		
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours						
	_		511	GWS Serving More Than 3,300		I
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at a reporting month? ☐ Yes ☒ No		ny time this	Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hocontinuous monitoring equipment was returned to Yes No			Date it was returned to service:
			Attach grab sample results and submit them with		vith this form.	1 1
Printed N	Name: Paul C	Diffney O	Title	e: Manager	Operator Certification #:	
Signature	e: • 70		# Pho	ne #: (541) 479-7445		OR
Date: 08 / 08 / 2022 Small Groundwater System ⊠						