## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

Month/Year _11/2022 Entry Point: EP-B Required Minimum Residual 1.2 mg/L  Lowest free chlorine residual at entry point to distribution system (mg/L)  1 0845 1.5
Date Time Source(s) in use residual at entry point to distribution system (mg/L)
1 0845
1 10010
2 0910 1.5
3 0915 1.4
4 0900 1.3
5 1000 1.3
6 0910 1.3
7 0855 1.3
8 0900 1.3
9 0910 1.3
10 0850 1.3
11 0900 1.7
12 0915 1.7
13 0900 1.7
14 0905 1.7
15 0920 1.3
16 0910 1.3
17 0930 1.3
18 0940 1.3
19 0900 1.3
20 0900 1.2
21 0930 1.2
22 0900 1.5
23 0915 1.5
24 0840 1.5
25 0855 1.5
26 1400 1.4
27 0915 1.7
28 0930 1.7
29 0855 1.7
30 0950 1.3
31
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L?  Yes  No  If yes, what was the longest time period until the required level was restored?  hours
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300
If yes, did you monitor every four hours until the residual returned to mg/L?  Did continuous monitoring equipment fail at any time this reporting month? Yes No Date continuous monitoring equipment failed:
Attach those results and submit them with this form.  If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  Date it was returned to service:
Attach grab sample results and submit them with this form.
Printed Name: Paul Cuffney Operator Certification #:
Signature: - Caul Call Phone #: (541) 479-7445 OR
Date: 12 / 01 / 2022 Small Groundwater System ⊠