State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Beaver Creek RV Res	ort	PWS ID# 4 1 01333		
Month/Year _12/2022 Entry Point: EP-B Required Minimum Residual 1.2 mg/L						
Date	Time	Source(s) ii	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	0855			1.3		
2	0930			1.3		
3	0915			1.3		
4	0900			1.4		
5	1425			2.0		
6	0920			1.7		7
7	1415			2.0		
8	0920			1.7		
9	0900			1.3		
10	0900			1.3		
11	1445			1.4		
12	0855			1.4		
13	0900			1.7		
14	0910			1.7		
15	0855			1.7		
16	0915			1.5 1.5		
17	0900			1.5		
18	1130 0905			1.5		
19 20	0855			1.5		
21	0910			1.4	1,	
22	0855			1.7		
23	0910			1.7		
24	0930			1.7		
25	0910			1.6		
26	0840			1.6		
27	0855			1.6		
28	0825			1.6		
29	0910			1.6		
30	0930			1.3		
31	1130			1.3		
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time reporting month? ☐ Yes ☒ No		ny time this	Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours continuous monitoring equipment was returned to so Yes No			Date it was returned to service:
			Attach grab sample results and submit them with		with this form.	1 1
Printed Name: Paul Cuffney				e: Manager	Operator Certification #:	
Signatur		1 (10/1/	Pho	ne #: (541) 479-7445		OR
Date: 01 / 03 / 2023 Small Groundwater System ⊠						