## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Beaver Creek RV Resort PWS ID# 4 1 01333						1333
Month/Year _02/2023 Entry Po			int: EP-B	Required Minimum Residual 1.2 mg/L		
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L		Notes
1	0850			1.6		
2	0930			1.6		
3	0900			1.7		
4	0900			1.7		
5	1030			1.5		
6	0855		-	1.5		
7	0920			1.5		
8	0915			1.5		
9	0850			1.7		
10	0930			1.2		
11	0915			1.6		
12	0930			1.6		
13	0855			1.5		
14	0850			1.5		
15	0840	,		1.5		
16	0850			1.5		
17	0900			1.5		
18	0900			1.5		
19	0900			1.5		
20	0845			1.5		
21	0900			1.5		A-4-6-6-6-6-6-6-6-6-6-6-6-6-6-6-6-6-6-6-
22	0900			1.5		
23	0850			1.3		
24	0930			1.5		
25	0920			1.8		
26	0915			1.8		
27	0900			1.8		
28	0910			1.8		
29						
30						
31						
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L?  Yes  No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						00
_				Did continuous monitoring equipment fail at any time this		Date continuous monitoring
until the residual returned to mg/L?			reporting month?  Yes No		ary arrie aris	equipment failed:
		and submit them with		If yes, were grab samples collected every four hou		1 /
this form.			continuous mo	nitoring equipment was returned Yes No	ed to service?	Date it was returned to
						service:
			Allacti grab sa	Attach grab sample results and submit them with this form.		/ /
Printed Name: Paul Cuffney Title: Manager					Operator Certification #:	
Signatur	e: 100	n Cul	Pho	one #: (541) 479-7445	OR	
Date: 03	3 / 09 / 2023	,	1/		Small Gr	oundwater System 🖂