State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Beaver Creek RV Resort				PWS ID# 4 1 01333		
Month/	Year _03	/2023 Entry Poi	nt: EP-B	Required Minimum Residual 1.2 mg/L		
Date	Time	Source(s) ir	use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	0930			1.8		
2	0900			1.8		
3	0900			1.5		
4	0912			1.5		
5	1000			1.3		
6	0910			1.5		water-1940
7	0850			1.5		T. V
8	0900			1.5		
9	0850			1.5		
10	0930			1.5		
11	0900			1.5		
12	0900			1.5		
13	0910		-	1.5	-	
14	0850			1.5		
15	0855			1.5	-	
16	0900			1.3		
17	1000			1.5		
18	0900			1.3		
19	0930			1.3		
20	0900			2.0	-	
21	0855			1.5		
22	0840			1.5	-	
23	0850					
24	0900			1.8	-	
25	1110			1.5	-	
26	1030			1.5 1.5	-	
27	0900			1.5		
28	0850			1.5		
29	0850			1.5		
30	0850			1.3		
01 1000						
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						00
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No		ny time this	Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hontinuous monitoring equipment was returned Yes No		ed to service?	Date it was returned to service:
, ·			Attach grab sample results and submit them		with this form.	1 1
Printed Name. Paul Cuffney Title: Manager					Operator Certification #:	
Signature: Phone #: (541) 479-7445					OR	
Date: 04 / 04 / 2023					Small Groundwater System 🖂	