State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	n Name	Beaver Creek RV Res	sort	PWS ID# 4 1 01333			
Month/	Year _04	1/2023 Entry Po	nt: EP-B	Red	uired Minimum	Residual 1.2 mg/L	
Date	Time	Source(s) in	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	0925			1.3			
2	0900			1.3			
3	0855			1.3			
4	0800			1.3			
5	0905			1.3			
6	0815			1.3			
7	0900			1.5		~	
8	0925			1.5			
9	0900			1.5			
10	0910			1.5			
11	0945			1.5			
12	0945			1.3			
13	0900		-	1.3			
14	0900			1.3			
15	0900			1.3			
16	0900			1.3			
17	1015			1.3			
18	0930			1.5			
19	0900			1.5			
20	0935			1.5			
21	0902			1.5			
22	1100			1.5			
23	0845			1.3			
24	0850			1.3			
25	0910			1.3			
26	1110			1.3			
27	0935			1.3	1		
28	0930			1.3			
29	0845			1.3			
30	1340			1.3			
31	1040			1.0			
-	e chlorine re	sidual ever less than the	required minim	um residual of 1.2 mg/L?	∕es ⊠ No		
				-	2 710		
If yes, what was the longest time period until the required level was restored? hours GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
				is monitoring equipment fail at a	Date continuous monitoring		
until the residual returned to mg/L?			reporting month? Yes No		equipment failed:		
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until th continuous monitoring equipment was returned to service? Yes No		ed to service?	Date it was returned to service:	
	1/2		Attach grab sample results and submit them with th		with this form.	I I	
Printed Name: Paul Cuffney, Title: Manager					Operator Certification #:		
Signature: Pan (541) 479-7445					OR		
Date: 0	Date: 04 / 03 / 2023					Small Groundwater System ⊠	