## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Beaver Creek RV Resort PWS ID# 4 1 01333						
Month/	Year _10	/2023 Entry Po	int: EP-B	Required Minimum Residual 1.2 mg/L		
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L	)	Notes
1	1105			1.8		
2	0930			1.5		
3	0900			1.4		
4	0834			1.8		
5	0900			1.7		
6	0930			1.5		
7	0945			1.5		
8	0920			1.5		
9	0845			1.9		
10	0830			1.8		
11	0915			1.8		
12	1011			1.7		
13	0947			1.8		
14	0930			1.6		
15	0935			1.8		
16	1030			1.5		
17	0954			1.4		
18	1005			1.4		
19	0900			1.3		
20	1126			1.6		
21	0900			1.4		
22	0955			1.4		
23	0845			1.4		
24	1000			1.4		
25	0940			1.4		
26	1035			1.5 1.5		
27	0930			1.8		
28	0945 1015			1.8	-	
29 30	0930			1.8		
31	0930			1.8		
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L?  Yes  No If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
STATE OF						
If yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous monitoring equipment fail at any time reporting month? ☐ Yes ☒ No		iny time this	Date continuous monitoring equipment failed:
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  Yes No		Date it was returned to service:	
			Attach grab sample results and submit them w		with this form.	1 1
Printed N	Name: Sandy	Hanson	Title: Manager		Operator Certification #:	
Signatur	e: San	duth	Phone #: (541) 479-7445		OR	
		9			Small Groundwater System 🖂	
Date: 10 / 03 / 2023 Small Groundwater System 🖂						