

# Monthly Disinfection Report for Ground Water Systems

System Name

WHISPERING PINES

PWS ID# 41-01468

Month/Year

10/2021

Entry Point:

EP-B (pump house)

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:01	8963170	.49	10730
2	6:36	8973980	.50	7870
3	5:31	8988240	.47	6470
4	6:01	8991250	.48	3010
5	5:55	8996450	.49	5200
6	6:24	9000270	.49	3820
7	5:49	9004160	.48	3890
8	5:40	9007530	.49	3370
9	7:20	9013520	.46	5990
10	5:30	9015490	.48	1970
11	6:00	9022000	.49	6570
12	5:58	9028070	.49	6070
13	6:03	9032750	.47	4680
14	5:56	9036340	.51	3590
15	6:00	9037480	.49	3140
16	6:22	9041930	.42	2450
17	7:56	9046490	.56	4560
18	6:24	9052530	.49	6040
19	5:34	9056160	.51	3630
20	6:14	9059160	.49	3000
21	5:36	9061780	.39	2620
22	5:35	9065840	.53	4060
23	8:30	9067800	.49	1960
24	8:40	9070960	.51	3160
25	5:36	9076110	.49	5150
26	5:50	9067990	.42	8120
27	5:45	9080950	.49	12940
28	6:01	9084200	.51	3250
29	7:13	9087590	.49	5390
30	6:37	9091490	.57	1900
31	7:19	9092650	.47	1160

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?  
 Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_

Date it was returned to service: \_\_\_\_\_

Printed Name:

BOB DANIELS

Title:

LAC

Signature:

[Signature]

Phone #: (541) 944-5538

Operator Certification #: \_\_\_\_\_

OR

Small Groundwater System

*[Handwritten initials]*