

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Ground Water Systems

System Name WHISPERING PINES PWS ID# 41-01468
 Month/Year 5/22 Entry Point EP-13 (pump house) Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:52	9829580	.49	2390
2	5:58	9831970	.51	4220
3	5:57	9836190	.56	3790
4	5:59	9839980	.52	5240
5	5:58	9845220	.44	2660
6	11:20	9847880	.51	4510
7	6:30	9852390	.79	2630
8	7:00	9855020	.51	3570
9	5:56	9858590	.54	4870
10	5:59	9865280	.57	3330
11	5:31	9868610	.54	9410
12		ONLINE TO CITY WATER		
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to _____ mg/L?
 Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
 Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____/_____/_____
 Date it was returned to service: _____/_____/_____

Printed Name: Billy Daniels Title: DRC
 Signature: _____
 Date: 5/13/2022 Phone #: (541) 944-5538

Operator Certification #: _____
 OR
 Small Groundwater System