

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Ground Water Systems

REC'D MAY 04 2021

System Name

WHISPERING PINES

PWS ID# 41-01468

Month/Year

4/21

Entry Point

EP-B (pump house)

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	5:58	7720370		
2	5:59	7726880	.74	6510
3	6:10	7731120	.72	4240
4	7:46	7734500	.74	2380
5	6:13	7742190	.76	7690
6	5:58	7750670	.74	8500
7	6:04	7755860	.73	5170
8	6:01	7765800	.72	7410
9	5:58	7770340	.73	6540
10	10:50	7777310	.72	6970
11	7:40	7781350	.73	4040
12	6:01	7789350	.72	8000
13	5:58	7796450	.73	7100
14	6:03	7803550	.73	7100
15	6:04	7809840	.74	6290
16	6:04	7817810	.73	7980
17	5:59	7825060	.74	7240
18	7:14	7829930	.74	4800
19	6:04	7832310	.73	2380
20	6:03	7848940	.73	16130
21	6:56	7851650	.72	3210
22	11:56	7853560	.74	1910
23	10:30	7858660	.79	5100
24	10:45	7864950	.85	6920
25	11:00	7868900	.98	3950
26	11:14	7873110	.95	4,210
27	11:30	7876990	1.25	3,880
28	8 AM	788280	.80	3,290
29	12:30	7889120	.80	8,840
30	6:19	7897390	.85	8,270
31		7908200	.79	110810

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 if yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L?

Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?

Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____

Date it was returned to service: _____

Printed Name: BRYAN DANIELS

Title: JRC

Operator Certification #: _____

Signature: _____

Phone #: (541) 944-5538

OR

Date: 4/30/21

Small Groundwater System