

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name CSWA Chehalem Springs

PWS ID# 4 1 01518

Month/Year 08/2025

Entry Point: EP-A (Skelton)

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	12:40P	Skelton Spring	0.70	
2	10:15A	Skelton Spring	0.68	
3	04:05P	Skelton Spring	0.65	
4	06:40P	Skelton Spring	0.65	
5	10:30P	Skelton Spring	0.64	
6	04:20P	Skelton Spring	0.68	
7	05:40P	Skelton Spring	0.66	
8	08:15A	Skelton Spring	0.65	
9	10:50P	Skelton Spring	1.18	
10	02:25P	Skelton Spring	0.90	
11	04:15P	Skelton Spring	0.74	
12	07:50A	Skelton Spring	0.71	
13	08:05A	Skelton Spring	0.69	
14	09:10A	Skelton Spring	0.71	
15	04:30P	Skelton Spring	0.70	
16	08:10A	Skelton Spring	0.70	
17	03:50P	Skelton Spring	0.70	
18	07:55P	Skelton Spring	0.68	
19	08:15A	Skelton Spring	0.87	
20	10:25P	Skelton Spring	1.07	
21	07:50A	Skelton Spring	0.84	
22	07:30A	Skelton Spring	0.82	
23	03:15P	Skelton Spring	0.78	
24	08:40P	Skelton Spring	0.79	
25	02:10A	Skelton Spring	1.02	
26	12:15P	Skelton Spring	1.80	
27	11:45P	Skelton Spring	1.03	
28	08:25P	Skelton Spring	0.83	
29	04:40P	Skelton Spring	1.00	
30	08:15A	Skelton Spring	0.81	
31	06:15A	Skelton Spring	0.77	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours – If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Curtis Olson

Title: Compliance Manager

Operator Certification #: 216644

Signature: *Curtis Olson*

Phone #: (503) 554-8333

OR

Date: 09 / 10 / 2025

Small Groundwater System ☐

December 19, 2012