

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name CSWA Chehalem Springs

PWS ID# 4 1 01518

Month/Year 10/2023

Entry Point: EP-B (Snider)

Required Minimum Residual 0.14 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	08:28A	Snider Springs	1.60	
2	12:19A	Snider Springs	1.36	
3	01:41P	Snider Springs	1.38	
4	01:38P	Snider Springs	1.58	
5	07:17A	Snider Springs	1.56	
6	04:44A	Snider Springs	1.60	
7	05:00A	Snider Springs	2.02	
8	02:23A	Snider Springs	1.99	
9	04:38P	Snider Springs	1.94	
10	11:56A	Snider Springs	1.87	
11	03:53P	Snider Springs	1.77	
12	08:23A	Snider Springs	1.93	
13	09:09P	Snider Springs	1.91	
14	07:37A	Snider Springs	1.87	
15	08:10A	Snider Springs	1.89	
16	11:46P	Snider Springs	1.90	
17	05:19A	Snider Springs	1.83	
18	07:41A	Snider Springs	1.80	
19	06:37A	Snider Springs	1.85	
20	04:43A	Snider Springs	1.91	
21	11:50P	Snider Springs	1.86	
22	10:11P	Snider Springs	1.83	
23	01:03A	Snider Springs	1.82	
24	11:11P	Snider Springs	1.75	
25	08:24A	Snider Springs	1.72	
26	11:59P	Snider Springs	1.88	
27	10:56A	Snider Springs	1.77	
28	11:18P	Snider Springs	1.81	
29	07:55A	Snider Springs	1.74	
30	12:09P	Snider Springs	1.74	
31	11:27P	Snider Springs	1.79	

Was the chlorine residual ever less than the required minimum residual of 0.14 mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? 0 hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.14 mg/L as required?  Yes  No

*Attach those results and submit them with this form.*

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

*Attach grab sample results and submit them with this form.*

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: JJ Olson

Signature: *Jeffrey Olson*

Date: 11 / 07 / 2023

Title: Compliance Manager

Phone #: (503) 554-8333

Operator Certification #: 766039

OR

Small Groundwater System