State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name CSWA OLIVER SPRING PWS ID# 4 1 01519							
Month/	Year 1	1/2021 Entry Po	int: EP-A	Required Minimum Residual 0.20 mg/L			
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L		Notes	
1	8:00 A	Oliver Springs		2.19			
2	8:00 A	Oliver Springs		1.95			
3	8:00 A	Oliver Springs		2.08			
4	8:00 A	Oliver Springs	Oliver Springs				
5	8:00 A	Oliver Springs					
6	8:00 A	Oliver Springs		1.71			
7	8:00 A	Oliver Springs		1.57			
8	8:00 A	Oliver Springs		1.50			
9	8:00 A	Oliver Springs		1.43			
10	8:00 A	Oliver Springs		1.55			
11	8:00 A	Oliver Springs		1.49			
12	8:00 A	Oliver Springs		1.64			
13	8:00 A	Oliver Springs		1.77			
14	8:00 A	Oliver Springs		1.74			
15	8:00 A	Oliver Springs		1.75			
16	8:00 A	Oliver Springs		1.59			
17	8:00 A	Oliver Springs		1.48			
18	8:00 A	Oliver Springs		0.85			
19	8:00 A	Oliver Springs		0.87			
20	8:00 A	Oliver Springs		0.86			
21	8:00 A	Oliver Springs		0.90			
22	8:00 A	Oliver Springs		0.96			
23	8:00 A	Oliver Springs		1.02			
24	8:00 A	Oliver Springs		0.81			
25	8:00 A	Oliver Springs		0.89			
26	8:00 A	Oliver Springs		0.88			
27	8:00 A	Oliver Springs		0.79			
28	8:00 A	Oliver Springs		0.72			
29	8:00 A	Oliver Springs		0.70			
30	8:00 A	Oliver Springs		0.68			
31		-					
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GW	S Serving	3,300 or Fewer	GWS Serving I	More Than 3,	300		
If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No Attach those results and submit them with this form.			Did continuous monitoring equipment fail at any time this reporting month? \square Yes \square No N/A If yes, were grab samples collected every four hours until th continuous monitoring equipment was returned to service as required? \square Yes \square No N/A Attach grab sample results and submit them with this form.		ur hours until the ed to service as	Date continuous monitoring equipment failed: / Date it was returned to service: / /	
Printed I	Name: Aaroi	n Olson	Title: DRC		Operator Certification #: T-09128, D-08773		
Signatur	re: //	Icon Olser	Phone #: (503) 554-8333		OR		
Ŭ					Small Groundwater System		
Date. I	Date: 12 / 01 / 2021 Small Groundwater System L						