State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

| System Name CSWA OLIVER SPRING PWS ID# 4 1 01519 | | | | | | |
|--|------------------|----------------|--|--|--|---|
| Month/Year 08/2022 Entry Point: EP-A Required Minimum Residual 0.20 mg/L | | | | | | |
| Date | Time | Source(s) i | n use | Lowest free chlorine residual at entry point to distribution system (mg/L) | | Notes |
| 1 | 8:00 A | Oliver Springs | | 1.16 | | |
| 2 | 8:00 A | Oliver Springs | | 1.04 | | |
| 3 | 8:00 A | Oliver Springs | | 1.23 | | |
| 4 | 8:00 A | Oliver Springs | | 1.14 | | |
| 5 | 8:00 A | Oliver Springs | | 1.13 | | |
| 6 | 8:00 A | Oliver Springs | | 1.14 | | |
| 7 | 8:00 A | Oliver Springs | | 1.14 | | |
| 8 | 8:00 A | Oliver Springs | | 1.12 | | |
| 9 | 8:00 A | Oliver Springs | | 1.12 | | |
| 10 | 8:00 A | Oliver Springs | | 1.09 | | |
| 11 | 8:00 A | Oliver Springs | | 1.22 | | |
| 12 | 8:00 A | Oliver Springs | | 1.22 | | |
| 13 | 8:00 A | Oliver Springs | | 1.30 | | |
| 14 | 8:00 A | Oliver Springs | | 1.31 | | |
| 15 | 8:00 A | Oliver Springs | | 1.29 | | |
| 16 | 8:00 A | Oliver Springs | | 1.31 | | |
| 17 | 8:00 A | Oliver Springs | | 1.31 | | |
| 18 | 8:00 A | Oliver Springs | | 1.31 | | |
| 19 | 8:00 A | Oliver Springs | | 1.29 | | |
| 20 | 8:00 A | Oliver Springs | | 1.28 | | |
| 21 | 8:00 A | Oliver Springs | | 1.25 | | |
| 22 | 8:00 A | Oliver Springs | | 1.29 | | |
| 23 | 8:00 A | Oliver Springs | | 1.28 | | |
| 24 | 8:00 A | Oliver Springs | | 1.31 | | |
| 25 | 8:00 A | Oliver Springs | | 1.33 | | |
| 26 | 8:00 A | Oliver Springs | | 1.32 | | |
| 27 | 8:00 A | Oliver Springs | | 1.30 | | |
| 28 | 8:00 A | Oliver Springs | | 1.24 | | |
| 29 | 8:00 A | Oliver Springs | | 1.22 | | |
| 30 | 8:00 A | Oliver Springs | | 1.18 | | |
| 31 | 8:00 A | Oliver Springs | | 1.13 | | |
| Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No | | | | | | |
| If yes, what was the longest time period until the required level was restored? $If > 4$ hours, Drinking Water Program to be notified by end of next business day. | | | | | | |
| GWS Serving 3,300 or Fewer GWS Serving More Than 3,300 | | | | | | |
| • | | | | | | |
| If yes, did you monitor every four hours until the residual returned to mg/L | | | | monitoring equipment fail at a $2 \Box Yes \Box No$ | • | Date continuous monitoring equipment failed: |
| as required? | | | | | | |
| Attach those results and submit them with | | | If yes, were grab samples collected every four hours until the / / / continuous monitoring equipment was returned to service as Date it was returned to | | | |
| this form | | | continuous monitoring equipment was returned to service as prequired? \Box Yes \Box No N/A Service: | | | |
| N/A | | | Attach grab sample results and submit them with this form. | | | |
| Deletion 1 | Aleman Alexandre | Olaar | - | | | faction # T 00400 D 00770 |
| Printed Name: Aaron Olson | | | Title: DRC | | Operator Certification #: T-09128, D-08773 | |
| Signatur | re:(/ | con Olsen | Phone #: (503) 554-8333 | | OR | |
| Date: 09 | 9 / 08 / 2022 | | | | Small Groundwater System 🗌 | |