

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name CSWA OLIVER SPRING

PWS ID# 4 1 01519

Month/Year _11/2024

Entry Point: EP-A

Required Minimum Residual 0.2

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	04:10P	Oliver Springs	0.80	
2	03:30P	Oliver Springs	0.82	
3	03:55P	Oliver Springs	0.77	
4	05:30P	Oliver Springs	0.41	
5	08:30P	Oliver Springs	0.66	
6	10:55P	Oliver Springs	0.73	
7	11:17P	Oliver Springs	0.29	
8	12:00A	Oliver Springs	0.25	
9	12:00A	Oliver Springs	0.40	
10	10:20A	Oliver Springs	2.02	
11	10:20A	Oliver Springs	1.14	
12	12:00A	Oliver Springs	0.47	
13	10:30P	Oliver Springs	0.82	
14	01:55P	Oliver Springs	0.66	
15	09:45A	Oliver Springs	0.80	
16	10:05P	Oliver Springs	0.60	
17	09:10P	Oliver Springs	0.56	
18	12:00P	Oliver Springs	0.75	
19	06:55A	Oliver Springs	2.00	
20	07:10P	Oliver Springs	2.26	
21	11:55P	Oliver Springs	1.08	
22	11:50P	Oliver Springs	0.98	
23	11:55P	Oliver Springs	0.94	
24	05:45P	Oliver Springs	0.92	
25	08:15P	Oliver Springs	0.68	
26	12:15P	Oliver Springs	0.68	
27	12:00A	Oliver Springs	0.71	
28	12:15A	Oliver Springs	0.72	
29	11:00A	Oliver Springs	0.74	
30	02:25P	Oliver Springs	0.53	
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? 0 hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: JJ Olson

Title: Compliance Manager

Operator Certification #: 766039

Signature:

Jeffrey Olson

Phone #: (503) 554-8333

OR

Date: 12 / 10 / 2024

Small Groundwater System ☐