

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name Sunridge Estates Upper  
 Month/Year 7 / 2024 Entry Point: A

PWS ID# 41-01555

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 am	AA, AB, AC, AD, AE, AF, AG	0.55	
2			0.43	
3			0.40	
4			0.37	
5			0.43	
6			0.50	
7			0.41	
8			0.43	
9			0.40	
10			0.42	
11			0.39	
12			0.42	
13			0.41	
14			0.38	
15			0.47	
16			0.38	
17			0.37	
18			0.62	
19			0.59	
20			0.42	
21			0.41	
22			0.38	
23			0.36	
24			0.43	
25			0.28	
26			0.54	
27			0.46	
28			0.45	
29			0.50	
30			0.57	
31			0.52	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Matthew Snyder Title: operator Operator Certification #: D-08779  
 Signature: [Signature] Phone #: (541) 660-3359 OR  
 Date: 8/16/24 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@odhsoha.oregon.gov](mailto:dwp.dmce@odhsoha.oregon.gov); fax 971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.