

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Sunridge Estates Upper PWS ID# 41-01555
 Month/Year 8/2024 Entry Point: A Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	AD, AB, AC, AD, AE, AF, AG	0.30	
2			0.33	
3			0.42	
4			0.40	
5			0.38	
6			0.37	
7			0.56	
8			0.48	
9			0.43	
10			0.31	
11			0.65	
12			0.78	
13			0.72	
14			0.73	
15			0.56	
16			0.49	
17			0.53	
18			0.66	
19			0.74	
20			0.35	
21			0.42	
22			0.53	
23			0.51	
24			0.50	
25			0.69	
26			0.82	
27			0.73	
28			0.70	
29			0.63	
30			0.71	
31			0.74	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Matthew Snyder Title: operator Operator Certification #: D 08779
 Signature: [Signature] Phone #: (541) 660-3359 OR
 Date: 9/3/24 Small Groundwater System

Return by 10th of following month by either email dlwp.dmce@odhsoha.oregon.gov; fax 971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.