

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Sunridge Estates Upper

PWS ID# 41 - 01555

Month/Year 3 / 2025 Entry Point: A

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	AA, AB, AC, AD, AE, AF, AG	0.77	
2			0.72	
3			0.58	
4			0.66	
5			0.73	
6			0.55	
7			0.60	
8			0.73	
9			0.67	
10			0.69	
11			0.63	
12			0.51	
13			0.76	
14			0.63	
15			0.68	
16			0.52	
17			0.53	
18			0.45	
19			0.41	
20			0.39	
21			0.45	
22			0.43	
23			0.60	
24			0.62	
25			0.89	
26			0.58	
27			0.66	
28			0.70	
29			0.77	
30			0.74	
31			0.82	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours - If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Matthew Snyder
Signature: [Signature]
Date: 4 / 9 / 25

Title: operator
Phone #: (541) 660-3359

Operator Certification #: D-08779

OR

Small Groundwater System ☐

Return by 10th of following month by either email dlp.dmce@odhsoha.oregon.gov; fax 971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019