

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name Alicea Hatchery PWS ID# 4105063  
 Month/Year 6/24 Entry Point: Feed Room Sink Required Minimum Residual 3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8am	Feed Room Sink	0.8	
2	8am	"	0.8	
3	8am	"	0.8	
4	8am	"	0.8	
5	8am	"	0.8	
6	8am	"	0.8	
7	8am	"	0.8	
8	8am	"	0.8	
9	8am	"	0.8	
10	8am	"	0.8	
11	8am	"	0.8	
12	8am	"	0.8	
13	8am	"	0.8	
14	8am	"	0.8	
15	8am	"	0.8	
16	8am	"	0.8	
17	8am	"	0.8	
18	8am	"	0.8	
19	8am	"	0.8	
20	8am	"	0.8	
21	8am	"	0.8	
22	8am	"	0.8	
23	7:30am	"	0.8	
24	8am	"	0.8	
25	8am	"	0.8	
26	8am	"	0.8	
27	8am	"	0.8	
28	8am	"	0.8	
29	8am	"	0.8	
30	8am	"	0.8	
31				

Was the chlorine residual ever less than the required minimum residual of 3 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours -- If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_

Printed Name: William M. Frank Title: Mgr  
 Signature: [Signature] Phone #: (541) 487-7440  
 Date: 6/30/24

Operator Certification # 4105063  
 OR  
 Small Groundwater System