

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Ground Water Systems

System Name Alsea Hatchery PWS ID# 4105063
 Month/Year 8/24 Entry Point: Feed Room Sink Required Minimum Residual 3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1:30am	Feed Room Sink	3	
2	8am	"		
3	8am	"		
4	8am	"		
5	8am	"		
6	8am	"		
7	8am	"		
8	8am	"		
9	8am	"		
10	8am	"		
11	8am	"		
12	8am	"		
13	8am	"		
14	7:30am	"		
15	8am	"		
16	8am	"		
17	8am	"		
18	7:30am	"		
19	8am	"		
20	8am	"		
21	8am	"		
22	8am	"		
23	8am	"		
24	8am	"		
25	8am	"		
26	8am	"		
27	8am	"		
28	8am	"		
29	8am	"		
30	8am	"		
31	8am	"		

Was the chlorine residual ever less than the required minimum residual of 3 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/____</p> <p>Date it was returned to service: _____/_____/____</p>
--	--	---

Printed Name: William M. Frank Title: Mgr Operator Certification #: 4105063
 Signature: [Signature] Phone #: (541) 487-7240 OR
 Date: 8/31/24 Small Groundwater System