

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Alicea Hatchery

PWS ID# 4105063

Month/Year 3/25 Entry Point: Feed Room Sink

Required Minimum Residual 3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8am	Feed Room Sink	.8	
2	8am	"	.8	
3	8am	"	.8	
4	8am	"	.8	
5	8am	"	.8	
6	8am	"	.8	
7	8am	"	.8	
8	8am	"	.8	
9	8am	"	.8	
10	8am	"	.8	
11	8am	"	.8	
12	8am	"	.8	
13	7:30am	"	.8	
14	8:00am	"	.8	
15	8am	"	.8	
16	8am	"	.8	
17	8am	"	.8	
18	8am	"	.8	
19	7:30am	"	.8	
20	8am	"	.8	
21	8am	"	.8	
22	8am	"	.8	
23	8am	"	.8	
24	8am	"	.8	
25	8am	"	.8	
26	8am	"	.8	
27	8am	"	.8	
28	8am	"	.8	
29	8am	"	.8	
30	8am	"	.6	
31	8am	"	.8	

Was the chlorine residual ever less than the required minimum residual of 3 mg/L? ☐ Yes ☒ No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____

Date it was returned to service: _____

Printed Name: William M. Frank

Signature: [Signature]

Date: 3/31/25

Title: Mgr

Phone #: (541) 487-7440

Operator Certification # 4105063

OR

Small Groundwater System ☐