

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Cold Springs PWS ID# 41 05201
 Month/Year 7 124 Entry Point: _____ Required Minimum Residual  mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4		1.90	
2	4		1.85	
3	4		1.85	
4	4		1.75	
5	4		1.75	
6	4		1.70	
7	4		1.70	
8	2		1.67	
9	2		1.60	
10	2		1.55	
11	2		1.59	
12	2		1.62	
13	2		1.55	
14	2		1.57	
15	2		1.46	
16	2		1.41	
17	2		1.38	
18	2		1.32	
19	2		1.40	
20	2		1.35	
21	2		1.35	
22	2		1.43	
23	2		1.52	
24	2		1.60	
25	2		1.62	
26	2		1.64	
27	10		1.62	
28	10		1.60	
29	10		1.64	
30	10		1.58	
31	10		1.62	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	--	---

Printed Name: Lisa Grigg Title: Accounting Clerk Operator Certification #: _____
 Signature: [Signature] Phone #: (503) 985-7561 OR
 Date: 8 15 124 Small Groundwater System