

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Murphy Trailer Park PWS ID# 41 05280
 Month/Year 11/21 Entry Point: Well #1 Required Minimum Residual 0.5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	5:40	#1	0.6	
2	6:12	TANK	0.7	
3	20:04	TANK	0.7	
4	9:15	TANK	0.7	
5	13:01	#3	0.7	
6	4:28	TANK	0.7	
7	9:25	TANK	0.7	
8	10:09	#4	0.7	
9	11:23	TANK	0.7	
10	10:10	#2	0.7	
11	4:21	TANK	0.7	
12	5:10	TANK	0.7	
13	9:42	#5	0.7	
14	3:01	TANK	0.7	
15	10:25	TANK	0.7	
16	4:11	#3	0.6	
17	10:09	TANK	0.6	
18	9:42	#4	0.6	
19	11:07	TANK	0.6	
20	3:58	TANK	0.6	
21	4:28	#5	0.6	
22	9:52	TANK	0.6	
23	10:19	TANK	0.6	
24	3:23	#2	0.6	
25	2:41	#1	0.6	
26	4:23	TANK	0.7	
27	1:07	#3	0.7	
28	9:51	TANK	0.7	
29	12:05	#5	0.7	
30	1:33	TANK	0.7	
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/_____</p> <p>Date it was returned to service: _____/_____/_____</p>
--	--	---

Printed Name: MIAN HOEFFLINGER Title: OWNER Operator Certification #: _____
 Signature: Alan Hoeflinger Phone #: (541) 659-2503 OR
 Date: 11/30/21 Small Groundwater System