

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

M.H.S.

System Name **Siuslaw Marina**

PWS ID# **41 05289**

Month/Year **9/23** Entry Point **EP-A**

Required Minimum Residual **0.4 mg/L**

Date	Time	Source(s) in use <i>KITCHEN TAP</i>	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:40 AM	"	0.7	
2	8:55 "	"	0.7	
3	7:10 "	"	0.7	
4	8:25 "	"	0.7	
5	8:00 "	"	0.6	
6	7:55 "	"	0.6	
7	8:30 "	"	0.6	
8	8:10 "	"	0.5	
9	8:45 "	"	0.5	
10	8:35 "	"	0.7	
11	8:20 "	"	0.7	
12	9:00 "	"	0.7	
13	8:40 "	"	0.7	
14	8:10 "	"	0.8	
15	8:30 "	"	0.7	
16	8:50 "	"	0.7	
17	8:45 "	"	0.6	
18	9:05 "	"	0.4	
19	8:15 "	"	0.4	
20	7:35 "	"	0.5	
21	6:40 "	"	0.6	
22	6:30 "	"	0.7	
23	8:10 "	"	0.5	
24	9:30 "	"	0.4	
25	9:00 "	"	0.4	
26	7:50 "	"	0.4	
27	8:45 "	"	0.5	
28	8:40 "	"	0.7	
29	8:05 "	"	0.7	
30	8:00 "	"	0.7	
31				

Was the chlorine residual ever less than the required minimum residual of **0.4** mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: **MARJORIE HANSEN** Title: **OWNER** Operator Certification #: _____
 Signature: *Marjorie Hansen* Phone #: **(541) 997-3254** OR
 Date: **10/3/23** CELL **541-999-1333** Small Groundwater System