

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Alesea Riviera Improvement Dist
 Month/Year 9 2021 Entry Point:

PWS ID# 41 05346
 Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1			1.8	
2			1.8	
3			1.8	
4			1.8	
5			2.0	
6			2.6	
7			2.8	
8			3.0	
9			3.2	
10			3.2	
11			2.8	
12			2.6	
13			2.4	
14			2.0	
15			1.8	
16			1.6	
17			1.6	
18			1.4	
19			1.4	
20			1.4	
21			1.2	
22			1.2	
23			1.2	
24			1.2	
25			1.2	
26			1.2	
27			1.2	
28			1.2	
29			1.2	
30			1.2	
31				

RECEIVED
 OCT 06 2021
 Data Mgmt & Compliance
 Drinking Water Program

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	--	---

Printed Name: JOHN WORTH Title: PRES. Operator Certification #: _____
 Signature: John M. Worth Phone #: (503) 803-5338 OR

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

Date: 10 10 11 21

Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694;
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019