

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **Alsea Riviera Water Improvement District**

PWS ID# **41 05346**

Month/Year **04 12 2022** Entry Point:

Required Minimum Residual **0.40 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1			.08	
2			.08	
3			.08	
4			.08	
5			.08	
6			.08	
7			.08	
8			.08	
9			.08	
10			.08	
11			.08	
12			.08	
13			.08	
14			.08	
15			.08	
16			.08	
17			.08	
18			.07	
19			.07	
20			.06	
21			.06	Add chlorine
22			.07	
23			.08	
24			.08	
25			.08	
26			.08	
27			.08	
28			.08	
29			.08	
30			.08	
31			.08	

RECEIVED
MAY 04 2022

Data Mgmt & Compliance
Drinking Water Program

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach those results and submit them with this form.	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: _____ / _____ / _____ Date it was returned to service: _____ / _____ / _____

Printed Name:

JOHN WORTH

Title:

PRESIDENT

Operator Certification #:

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

Date: 051 021 22 John M. Wozel Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694;
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019

503-803-5338

RECEIVED
MAY 04 2022

Data Mgmt & Compliance
Drinking Water Program