

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

**RECEIVED**

FEB 05 2024

System Name Alesea Riviera Water Improvement District

PWS ID# 4 1 05346

Certification  
 Drinking Water Services

Month/Year 01/24 Entry Point:

Required Minimum Residual 0.40 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1			.08	
2			.08	
3			.08	
4			.08	
5			.08	
6			.08	
7			.08	
8			.08	
9			.08	
10			.08	
11			.08	
12			.08	
13			.08	
14			.08	
15			.08	
16			.08	
17			.08	
18			.08	
19			.08	
20			.08	
21			.08	
22			.08	
23			.08	
24			.08	
25			.08	
26			.08	
27			.08	
28			.08	
29			.08	
30			.08	
31			.08	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No

*Attach those results and submit them with this form.*

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

*Attach grab sample results and submit them with this form.*

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: JOHN M. WORTH

Title: PRESIDENT

Operator Certification #:

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

Date: 02 10 3 1 24

Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694;  
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019

John M. Worth

503-803-5338

RECEIVED

FEB 05 2024

Certification  
Drinking Water Services