

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Sunridge Estates
Month/Year 5 / 2021 Entry Point: A

PWS ID# 41-05567

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	AA, AB, AC, AD	0.37	
2			0.46	
3			0.98	
4			1.04	
5			0.92	
6			0.99	
7			0.82	
8			1.09	
9			1.11	
10			1.16	
11			0.97	
12			0.82	
13			0.53	
14			0.57	
15			0.68	
16			0.67	
17			0.72	
18			0.79	
19			0.62	
20			0.69	
21			0.55	
22			0.59	
23			0.61	
24			0.50	
25			0.82	
26			0.97	
27			0.93	
28			0.94	
29			0.90	
30			0.82	
31			0.88	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	---	---

Printed Name: Matthew Snyder Title: operator Operator Certification #: D-08779
Signature: [Signature] Phone #: (541) 660-3359 OR
Date: 6/10/21 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.