

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name

PWS ID# 41-05567

Month/Year 8/21 Entry Point: A

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	AA, AB, AC, AD	0.78	
2			0.68	
3			0.78	
4			0.56	
5			0.55	
6			0.57	
7			0.59	
8			0.59	
9			0.58	
10			0.57	
11			0.50	
12			0.80	
13			0.75	
14			0.71	
15			0.64	
16			0.63	
17			0.67	
18			0.59	
19			0.49	
20			0.63	
21			0.71	
22			0.79	
23			0.82	
24			0.88	
25			0.81	
26			0.76	
27			0.72	
28			0.76	
29			0.73	
30			0.68	
31			0.47	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	---	---

Printed Name: Matthew Snyder Title: operator Operator Certification #: D-08779
 Signature: [Signature] Phone #: (541) 660-3359
 Date: 9/10/21

OR
Small Groundwater System

Return by 10th of following month by either email dlwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.