

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Sunridge Estates
Month/Year 11/122 Entry Point: A

PWS ID# 41 05567
Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:20 AM	AA, AB, AC, AD	0.72	
2			0.53	
3			0.52	
4			0.68	
5			0.47	
6			0.52	
7			0.59	
8			0.48	
9			0.60	
10			0.61	
11			0.64	
12			0.68	
13			0.75	
14			0.48	
15			0.26	
16			0.59	
17			0.46	
18			0.54	
19			0.70	
20			0.62	
21			0.67	
22			0.49	
23			0.58	
24			0.62	
25			0.60	
26			0.65	
27			0.62	
28			0.54	
29			0.58	
30			0.71	
31			0.64	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Matthew Smpler Title: operator Operator Certification #: D-08779
Signature: [Signature] Phone #: (541) 660 3359 OR
Date: 219 122 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.