

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Sunridge Estates
Month/Year 3 / 2022 Entry Point: A

PWS ID# 41-05567
Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00	AA, AB, AC, AD	0.90	
2			0.87	
3			0.84	
4			0.84	
5			0.82	
6			0.78	
7			0.83	
8			0.79	
9			0.83	
10			0.69	
11			0.82	
12			0.81	
13			0.68	
14			0.79	
15			1.12	
16			1.01	
17			1.05	
18			0.96	
19			0.84	
20			0.78	
21			0.74	
22			0.81	
23			0.63	
24			0.49	
25			1.18	
26			0.95	
27			0.92	
28			1.01	
29			0.96	
30			0.87	
31			0.75	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>		<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>		<p>Date continuous monitoring equipment failed:</p> <p> / /</p> <p>Date it was returned to service:</p> <p> / /</p>
--	--	--	--	---

Printed Name: Matthew Snyder Title: operator Operator Certification #: D-08779
Signature: [Signature] Phone #: (541) 660-3359 OR
Date: 4/4/2022 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.