

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Sunridge Estates Lower

PWS ID# 41-05567

Month/Year 1/2023 Entry Point: A

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM	AA, AB, AC, AD	0.53	
2			0.53	
3			0.52	
4			0.49	
5			0.60	
6			0.59	
7			0.55	
8			1.18	
9			0.51	
10			0.66	
11			0.63	
12			0.84	
13			0.44	
14			0.68	
15			0.77	
16			0.80	
17			0.52	
18			0.85	
19			0.79	
20			0.52	
21			0.53	
22			0.45	
23			0.58	
24			0.70	
25			0.53	
26			0.75	
27			0.77	
28			0.36	
29			0.64	
30			0.85	
31			0.81	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	---	---

Printed Name: <u>Matthew Snyder</u> Signature: <u>[Signature]</u> Date: <u>2/10/23</u>	Title: <u>operator</u> Phone #: <u>(541) 660-3359</u>	Operator Certification #: <u>D-08779</u> OR Small Groundwater System <input type="checkbox"/>
--	--	---

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.