

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name Sunridge Estates Lower

PWS ID# 41-05567

Month/Year 2 / 2026 Entry Point: A

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	<u>8:00 AM</u>	<u>AA, AB, AC, AD</u>	<u>0.68</u>	
2			<u>0.73</u>	
3			<u>0.81</u>	
4			<u>0.75</u>	
5			<u>0.77</u>	
6			<u>0.72</u>	
7			<u>0.58</u>	
8			<u>0.80</u>	
9			<u>0.87</u>	
10			<u>0.86</u>	
11			<u>0.83</u>	
12			<u>0.72</u>	
13			<u>0.94</u>	
14			<u>1.04</u>	
15			<u>1.09</u>	
16			<u>0.98</u>	
17			<u>0.92</u>	
18			<u>0.95</u>	
19			<u>0.91</u>	
20			<u>0.77</u>	
21			<u>0.87</u>	
22			<u>0.84</u>	
23			<u>0.52</u>	
24			<u>0.70</u>	
25			<u>0.67</u>	
26			<u>0.84</u>	
27			<u>0.62</u>	
28			<u>0.90</u>	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	---	---

Printed Name: Matthew Smyler Title: operator Operator Certification #: D-68779  
 Signature: [Signature] Phone #: (541) 660-3359 OR  
 Date: 3/9/26 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@odhsoha.oregon.gov](mailto:dwp.dmce@odhsoha.oregon.gov); fax 971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.