

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Westridge Subdivision

PWS ID# 4 1 05998

Month/Year June 2021 Entry Point: EP-A (EP for Well)

Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 am	Well	.6	
2	8:15	"	.6	
3	8:15	"	.5	
4	8:00	}	.6	
5	8:10		.7	
6	8:00		.6	
7	8:30		.6	
8	8:30		.5	
9	8:00		.6	
10	8:00		.6	
11	8:30		.5	
12	8:30		.5	
13	8:00		.6	
14	8:00		.6	
15	8:15		.7	
16	8:30		.6	
17	8:30		.6	
18	8:30		.5	
19	8:10		.5	
20	8:00		.6	
21	8:00		.6	
22	8:30		.5	
23	8:00		.6	
24	8:00		.5	
25	8:30		.6	
26	8:00		.6	
27	8:30		.6	
28	8:00		.7	
29	8:30		.7	
30	8:15		.6	
31	8:00		.6	

RECEIVED
 JUL 09 2021
 Data Mgmt & Compliance
 Drinking Water Program

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p align="center">GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>	

Printed Name: Wayne Looney Title: Cert. Operator Operator Certification #: _____
 Signature: Wayne Looney Phone #: (503) 815-4478 OR
 Date: 7/3/21 Small Groundwater System

Return by 10th of following month by either email dwp.dnce@dhsosha.state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.