

State of Oregon Drinking water Program
Monthly Disinfection Report for Ground Water Systems

System Name Westridge Subdivision

PWS ID# 4 1 05998

Month/Year Oct / 2021 Entry Point: EP-A (EP for Well)

Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:15	Westridge Well	.7	
2	8:00	"	.6	
3	8:30		.6	
4	8:00	"	.5	
5	8:30		.6	
6	8:30	"	.7	
7	8:00		.6	
8	8:00		.6	
9	8:30		.5	
10	9:00		.6	
11	8:00		.6	
12	8:15		.7	
13	8:30		.6	
14	8:30		.6	
15	8:15		.5	
16	8:30		.4	
17	9:00		.6	
18	8:30		.6	
19	8:30		.7	
20	8:15		.7	
21	8:00		.4	
22	9:00		.6	
23	8:15		.5	
24	9:00		.6	
25	8:00		.6	
26	8:00		.7	
27	8:30		.8	
28	8:30		.5	
29	8:15		.6	
30	8:30		.6	
31	9:00		.7	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	--	---

Printed Name: Wayne Lowrey Title: System Operator Operator Certification #: _____
 Signature: Wayne Lowrey Phone #: (541) 815-4478 OR
 Date: 11 / 4 / 21 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@dhsosha.state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.