

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name **Westridge Subdivision** PWS ID# **41 05998**  
 Month/Year **/** Entry Point: **EP-A (EP for Well)** Required Minimum Residual **0.4 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:30	Westridge Well	.5	
2	8:00		.4	
3	8:00		.4	
4	8:15		.4	
5	9:30		.6	
6	8:15		.6	
7	8:00		.5	
8	8:30		.4	
9	9:00		.6	
10	8:15		.7	
11	8:00		.5	
12	10:00		.5	
13	8:15		.6	
14	8:30		.4	
15	8:10		.7	
16	8:00		.5	
17	8:15		.5	
18	8:30		.6	
19	10:00		.5	
20	8:00		.6	
21	8:00		.7	
22	8:15		.7	
23	8:30		.6	
24	8:30		.6	
25	8:00		.5	
26	11:00		.5	
27	8:30		.6	
28	8:30		.7	
29	8:00		.7	
30	8:30		.6	
31				

**RECEIVED**  
 JUL 07 2022  
 Data Mgmt & Compliance  
 Drinking Water Program

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>
--	--	---

Printed Name: **Wayne Looney** Title: **Water Officer** Operator Certification #: \_\_\_\_\_  
 Signature: *Wayne Looney* Phone #: **(541) 815-4478** OR  
 Date: **8/4/22** Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwa.dince@dnr.state.or.us](mailto:dwa.dince@dnr.state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.