

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **Westridge Subdivision** PWS ID# **4 1 05998**
 Month/Year **Jan / 2024** Entry Point: **EP-A (EP for well)** Required Minimum Residual **0.4 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0700		0.6	Emailed on 02/04/24
2	0715		0.6	
3	0800		0.7	
4	0830		0.9	
5	1:30 PM		0.8	
6	0730		0.8	
7	1000		0.7	
8	1010		0.7	
9	1:00 PM		0.9	
10	0845		1.2	
11	0930		0.9	
12	0830		0.6	
13	0700		0.5	
14	0600		0.5	
15	0615		0.8	
16	0700		0.5	
17	0930		0.9	
18	0800		1.2	
19	1:30 PM		1.0	
20	0745		0.8	
21	0745		0.6	
22	0745		0.4	
23	0815		0.7	
24	0630		0.9	
25	1100		0.9	
26	0845		0.8	
27	0800		1.0	
28	0900		0.7	
29	1030		1.1	
30	2:30 PM		0.5	
31	0745		0.5	

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours **Drinking Water Program to be notified by end of next business day.**

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No
Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /
 Date it was returned to service: / /

Printed Name: WILLIAM W FRANSEN

Title: SWSO

Operator Certification #:

Signature: _____

Phone #: (360) 951-2683

OR

Date: 02 / 04 / 2024

Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.