

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems


System Name Westridge Subdivision		PWS ID# 4 1 05998	
Month/Year May / 2024		Entry Point: EP-A (EP for well)	
		Required Minimum Residual 0.4 mg/L	

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0630		0.74	Emailed on 06/03/24
2	0630		0.68	
3	0900		0.54	
4	0600		0.80	
5	0715		0.55	
6	3:00 PM		0.68	
7	0600		0.66	
8	0615		0.93	
9	0645		0.48	
10	0630		0.76	
11	0700		0.80	
12	0730		0.61	
13	0600		0.70	
14	0600		0.58	
15	0800		0.88	
16	0800		0.75	
17	0715		0.90	
18	0600		0.54	
19	0900		0.81	
20	1000		0.83	
21	1000		0.60	
22	1:00 PM		0.79	
23	0800		1.10	
24	0600		0.90	
25	0745		0.78	
26	800		1.1	
27	0730		0.49	
28	0900		0.55	
29	1:00 PM		0.79	
30	830		0.89	
31	0930		0.96	

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>
<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>	

Printed Name: WILLIAM W. FRANSEN Signature:  Date: 06/03/2024	Title: SWSO Phone #: (360) 951-2683	Operator Certification #: _____ OR Small Groundwater System <input type="checkbox"/>
--	--	--

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.