

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Westridge Subdivision	PWS ID# 4 1 05998
Month/Year Oct / 2024 Entry Point: EP-A (EP for well)	Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0600		0.72	Emailed on 11/04/24
2	0615		0.93	
3	0615		0.91	
4	0800		0.73	
5	0800		0.80	
6	0800		0.88	
7	0615		0.76	
8	0615		0.70	
9	0630		0.65	
10	0900		0.56	
11	1:00 PM		0.92	
12	0615		1.12	
13	0615		1.08	
14	0700		0.93	
15	0615		0.87	
16	0915		0.78	
17	0615		0.98	
18	0615		1.24	
19	0800		1.30	
20	0745		0.92	
21	0800		0.76	
22	0815		0.71	
23	0615		0.83	
24	0630		0.91	
25	1000		0.65	
26	0800		0.59	
27	0615		0.66	
28	0615		0.76	
29	0700		0.83	
30	0630		0.59	
31	2:30 PM		0.69	

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes NoX
 If yes, what was the longest time period until the required level was restored? hours – if > 4 hours Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:</p> <p align="center">/ /</p> <p>Date it was returned to service:</p> <p align="center">/ /</p>
---	---	---

Printed Name: WILLIAM W FRANSEN	Title: SWSO	Operator Certification #:
Signature:	Phone #: (360) 951-2683	OR
Date: 11 / 04 / 2024		Small Groundwater System <input type="checkbox"/>

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.